

Lead Test Results

The Office of Childcare requires that we test our water for lead, minimally every 6 years, and share the results. Our most recent lead test is posted below.

Further Information about Lead and Public Health:

The public health goal for lead in water is zero parts per billion or PPB. The reality is that a “0” is nearly impossible to attain. The Portland Water Bureau considers all water with a lead level of 3.8 PPB or below to be safe.

“ND” on a lead report means “non-detectable.” Taps receiving a lead reading of “ND” have a lead level is so small that it cannot be detected by testing. In our latest lead report, all of the taps which provide water to the children are “ND” for lead. One tap in our administrative building received a reading of 3.0 PPB; however, the children do not use water from that building.

Lead Resources:

The Environmental Protection Agency: <https://www.epa.gov/lead>

Multnomah County: <https://multco.us/health/lead-poisoning-prevention>

Multnomah County Lead Line: 503-988-4000

Portland Water Bureau: <https://www.portlandoregon.gov/water/29587>